

Certificate of Design, Installation and Commissioning of a Smoke/Heat Alarm System to Grade D1/D2 or F1/F2 as defined in BS 5839-6:2019+A1:2020

Address:
It is certified that the fire detection and fire alarm system at the above address compiles with the recommendations of BS 5839-6:2019+A1:2020, for design, installation and commissioning of a Grade Category System, other than in respect of the following variations:*
Brief description of areas protected (only applicable to category LD2 systems):
The entire system has been tested for satisfactory operation in accordance with the recommendations of 23.3p of BS 5839-6:2019+A1:2020,*.
The requirements of paragraph N) section 1) of Clause 23.3 have not been performed, having been substituted by following the Inspection and Testing Procedure recommendations contained within the Siting and Installation Instructions supplied by the manufacturer of the smoke/heat alarms installed.
Instructions in accordance with the recommendations of Clause 24 of BS 5839-6:2019+A1:2020, have been supplied to:*
Signed Date
For and on the behalf of

*Where design, installation and commissioning are not all the responsibility of a single organisation or person, the relevant words should be deleted. The signatory of the certificate should sign only as confirmation that the work for which they have been responsible complies with the relevant recommendations of BS 5839-6:2019+A1:2020, A separate certificate(s) should then be issued for other work.

This certificate might be required by an authority responsible for enforcement of fire safety legislation, such as building control authority or housing authority. The recipient of this certificate might rely on certificate as evidence of compliance with legislation. Liability could arise on the part of any organisation or person that issues a certificate without due care in ensuring its validity.

All variations should be agreed with all relevant parties beforehand.

This document is a template provided by Aico based on the Design, Installation and Commissioning Certificate template within Annex E of BS 5839-6:2019+A1:2020. Aico in no way provides any endorsement, approval or similar of any work carried out by the company or individual that has completed this document and accepts no responsibility or law issues or damaged caused from such work. All responsibility and liability regarding the product selection, use and installation is solely assigned to the company or individual that has completed this document.

Aico - Design, Installation & Commissioning Certificate - BS 5839-6:2019 +A1:2020 including variation. Issue: 8 - Date: 23/09/2025

